



*Smart Energy, Sustainable Future*

**LICENCE NO.                    EMA/GE/005**

**TYPE                                GENERATION**

**LICENSEE                        PACIFICLIGHT POWER PTE LTD**

**NOTIFICATION NO.            5**

1. Pursuant to Section 12 of the Electricity Act (Cap. 89A), PacificLight Power Pte Ltd is hereby notified that Condition 10 of Licence No. EMA/GE/005 is modified by substituting in its entirety with the following paragraphs:

"1. The Licensee shall take such action as the Authority may reasonably require, taking into consideration the provisions of the market rules related to emergency preparedness and restoration of the power system, to plan and prepare for emergencies, including taking part in tests and exercises.

2. The Licensee shall develop and implement such plans and arrangements as are prudent to ensure the safety, security and reliability of its operations at all times and, where reasonably practicable, the continuity of supply from its generating units in the event of an emergency taking into consideration the provisions of the market rules relating to emergency preparedness and restoration of the power system. In particular, the Licensee:

(a) must have, in total, enough fuel reserves to last at least 60 days for operation of the Licensee's authorised business or such amounts of fuel reserves as the Authority may specify;

(b) subject to paragraph 2(a) above, must have the exclusive right of use of fuel reserves on site to last at least 30 days for operation of the Licensee's authorised business or such amounts of fuel reserves as the Authority may specify;

(c) subject to any conditions as the Authority may specify, and to paragraphs 2(a) and 2(b) above, must have plans and arrangements to have its other fuel reserves located at the premises of its fuel supplier/vendor in Singapore where the said fuel reserves can be delivered from such premises to the

*Yls*

Licensee's generating station premises securely and reliably at all times to ensure continuous and uninterrupted operation of the Licensee's generating station, and must secure from the said fuel supplier/vendor the right of use upon demand over the said fuel reserves; and

- (d) must have the exclusive right of use of storage tank capacity on site to last at least 60 days for operation of the Licensee's authorised business or such storage tank capacity as the Authority may specify.

For the purposes of this Condition:

"on site" means at the Licensee's generating station premises or such other premises which are connected to the Licensee's generating station premises by dedicated pipeline, or at such other premises in Singapore as approved by the Authority and subject to any conditions as the Authority may specify, where fuel can be delivered from such premises to the Licensee's generating station premises securely and reliably at all times to ensure continuous and uninterrupted operation of the Licensee's generating station."

- 2. This Notification shall come into effect on the date set out below.

21 July 2016



NG WAI CHOONG  
Chief Executive  
Energy Market Authority of Singapore

